



No. MMDSL/1/pro/med/Equipment/2024(34)

Dated: 19/09/2024

CORRINGENDUM/ADDENDUM

Reference Tender Notice No: MMDSL/1/pro/med/Equipment/2024(21) dtd. 05/09/2024 the following reply and corrigendum/addendum to the Tender notice are hereby notified through this to all concerned based on the queries received.

Sl No	Tender Clause	Request/Clarifications	Reasons	Response
ITEM Name: 6 kVa UPS				
Point 33.	Battery Capacity and Number- Inbuilt 7AH* 16 No's	External 7AH x 16 Nos.	Inbuilt Batteries has limitations for proper servicing also battery capacity cannot be expanded in future	Optional.
Point 34.	Maximum charging current- 3.6 - 6.3 Amps	Max 8 Amps (Should be settable as per Battery AH Rating)	Since This is Lowest Battery Capacity, So, Battery Current Setting should be as per AH Only	Accepted.
Sl No	Tender Clause	Request/Clarifications	Reasons	Response
ITEM Name: 10 kVa UPS				
Point 33.	Battery Capacity and Number- Inbuilt 9AH* 16 No's	External 9AH x 16 Nos.	Inbuilt Batteries has limitations for proper servicing also battery capacity cannot be expanded in future	Optional
Point 34.	Maximum charging current- 5.2 - 10.4 Amps	Max 8 Amps (Should be settable as per Battery AH Rating)	Since This is Lowest Battery Capacity, So, Battery Current Setting should be as per AH Only should be as per AH Only	Accepted.



Approved By Shri Ramkumar S(Managing Director) on 19/09/2024 09:10 AM
(The document is digitally approved and does not require any Seal or Signature in original)

Sl No	Clause	Request/Clarifications	Reasons	Response
ITEM Name: 15/20 kVa UPS				
2 (d)	UPS should Coloured touch LCD with gravity sensor	UPS should Coloured LCD Display (Field Rotatable based on Rack or Tower Mounting)	Gravity Sensor LCD Display is Automatic Feature whether its Place in Rack (Horizontal Position), Tower (Vertical Position); Kindly amend as Field Settable(we can tilt the Display as per Mounting Position)	Accepted.
2 (e)	UPS Should be rack mount 3U rack height and should have feature of Paralleling up to 3 Units	UPS Should be rack mount 3U rack height and should have feature of Paralleling up to 3 Units	2U Consumes Less Space and Paralleling up to 4 Units is standard for 15KVA/20KVA UPS Systems	Accepted.
Sl.No	Tender Clause	Request/Clarifications	Reasons	Response
ITEM Name: 30 kVa UPS				
KVA/KW Rating	30KVA /24KW	30KVA /27KW or Better	It will be able to give more power Output in same Rating	Accepted.
Input frequency	Input Frequency : 40 to 72Hz	Input Frequency : 40 to 70Hz	Widest Frequency range ever designed is 40-70 Hz	Accepted.

ADDENDUM: -

- 1. Bidder may choose to quote only for 1 or more sections. However, the Bidder has to quote for all the products from the particular sections he/she wishes to quote.**
- 2. The Bidder should Submit the Valid Licenses needed for Electrical Installations**



MEGHALAYAN MEDICAL DRUGS & SERVICES LIMITED



Government of Meghalaya

Department of Health & Family Welfare,
DHS Complex, New Colony, Laitumkrah,
Shillong - 793003,
East Khasi Hills,
Meghalaya.

+91-9863033404 / 9863048955
meghmdsl@gmail.com

Shri Ramkumar S
Managing Director

Approved By Shri Ramkumar S (Managing Director) on 19/09/2024 09:10 AM
(The document is digitally approved and does not require any Seal or Signature in original)